

Modelling and power control of grid-connected wind energy system

Nadia Ben Si Ali*, Badji Mokhtar Annaba University, P.O. Box 12 Sidi Ammar, Annaba 23000, Algeria

Nora Zerzouri, Badji Mokhtar Annaba University, P.O. Box 12 Sidi Ammar, Annaba 23000, Algeria

Nadia Benalia, Badji Mokhtar Annaba University, P.O. Box 12 Sidi Ammar, Annaba 23000, Algeria

Suggested Citation:

Ben Si Ali, N., Zerzouri, N. & Benalia, N. (2018). Modeling and power control of grid-connected wind energy system. *Global Journal of Computer Sciences: Theory and Research*. 8(2), 87–95.

Received from October 28, 2017; revised from March 12, 2018; accepted from August, 25, 2018.

Selection and peer review under responsibility of Prof. Dr. Dogan Ibrahim, Near East University, Cyprus.

©2018 SciencePark Research, Organization & Counseling. All rights reserved.

Abstract

Wind energy generation has attracted great interests in recent years. Doubly fed induction generator (DFIG) for wind turbines are largely deployed because variable-speed wind turbines have many advantages over fixed-speed generation such as increased energy capture, operation at maximum power point, improved efficiency and power quality. This paper presents the operation and vector control of a DFIG system where the stator is connected directly to a stiff grid and the rotor is connected to the grid through bi-directional back-to-back AC–DC–AC converter. The basic operational characteristics, mathematical model of the aerodynamic system and vector control technique, which are used to obtain decoupled control of powers, are investigated using the software Matlab/Simulink.

Keywords: Wind turbine, doubly fed induction generator, active and reactive power controller.

* ADDRESS FOR CORRESPONDENCE: **Nadia Ben Si Ali**, Badji Mokhtar Annaba University, P.O. BOX 12 Sidi Ammar, Annaba 23000, Algeria. **E-mail address:** bensialin@yahoo.fr / Tel.: (+213)38-872-678

1. Introduction

Wind energy is a renewable source of electricity which is exploited by converting the kinetic energy of moving air into electricity. Doubly fed induction generators (DFIG) are the most commonly used wind turbine technology because the turbine speed can be adjusted as a function of wind speed in order to maximise the output power [1]. It is an attractive and popular option for large wind turbines multi-MW. One of the main advantages of adjustable speed generators is improving the system efficiency compared with fixed speed generators. The DFIG wind turbine control system generally consists of two parts: the electrical control on the DFIG and the mechanical control of the wind turbine blade pitch angle. Control of the DFIG is achieved by controlling the variable frequency converter, which includes the control of the rotor-side converter (RSC) and the control of the grid-side converter (GSC). The objective of the RSC is to govern both the stator-side active and reactive powers independently, while the objective of the GSC is to keep the DC-link voltage constant regardless of the magnitude and direction of the rotor power. The GSC control scheme can also be designed to regulate the reactive power or the stator terminal voltage of the DFIG. The RSC control scheme should be designed in order to regulate the wind turbine speed for maximum wind power capture. Therefore, a suitably designed speed controller is essential to track the optimal wind turbine reference speed for maximum wind power extraction [2]. Variable speed operation of a wind turbine is necessary to increase the power generation efficiency, so this system requires a suitable speed controller in order to track the optimal reference speed of the wind turbine in order to maximise the output power [3, 4].

In this paper, after modelling the DFIG and choosing the appropriate $d-q$ reference frame, the rotor is supplied by an inverter on two levels controlled by pulse width modulation (PWM) technique. The active and reactive powers are controlled using proportional–integral (PI) controllers.

2. System description

The VSWT consists of stator windings connected directly to the grid and wound rotor windings connected to a power converter. Variable speed generator permits the maximum energy captured from a wind turbine. The generator rotor speed is controlled to operate within a variable speed range centered around the generator synchronous speed (Figure 1) [5, 6].




Figure 1. Schematic diagram of DFIG-based wind turbine

3. Doubly fed induction generator modelling

The dynamic equation of a three-phase DFIG can be written in a synchronously rotating $d-q$ reference frame as:

$$\underline{u}_s = R_s \underline{i}_s + \frac{d}{dt} \underline{\psi}_s + j\omega_s \underline{\psi}_s \quad (1a)$$

$$\underline{u}_r = R_r \underline{i}_r + \frac{d}{dt} \underline{\psi}_r + j(\omega_s - \omega) \underline{\psi}_r \quad (1b)$$

where

$\underline{u}_s = u_{sd} + ju_{sq}$, $\underline{u}_r = u_{rd} + ju_{rq}$: stator and rotor voltage vectors

$\underline{i}_s = i_{sd} + ji_{sq}$, $\underline{i}_r = i_{rd} + ji_{rq}$: stator and rotor current vectors

$\underline{\psi}_s = \psi_{sd} + j\psi_{sq}$, $\underline{\psi}_r = \psi_{rd} + j\psi_{rq}$: stator and rotor flux vectors

L_s, L_r, L_m : stator, rotor and mutual inductances, respectively.

R_s, R_r : stator and rotor resistances

ω_s, ω : stator angular frequency and motor angular velocity, respectively.

Stator and rotor flux linkages are:

$$\underline{\psi}_s = L_s \underline{i}_s + L_m \underline{i}_r \quad (2a)$$

$$\underline{\psi}_r = L_r \underline{i}_r + L_m \underline{i}_s \quad (2b)$$

Electromagnetic torque equation is:

$$T_{em} = p \frac{L_m}{L_r} (\psi_{rd} i_{sq} - \psi_{rq} i_{sd}) \quad (3)$$

4. Basic concepts of wind turbine

The aerodynamic model of a wind turbine can be characterised by the well-known $C_p = f(\lambda - \beta)$ curves. C_p is the power coefficient, which is a function of both *tip-speed ratio* λ and the *blade pitch angle* β . The tip-speed ratio λ is defined by:

$$\lambda = \frac{\Omega_t R}{v} \quad (4)$$

Where R is the blade length in m , Ω_t is the wind turbine rotational speed in rad/s, and v is the wind speed in m/s. The power coefficient C_p gives the fraction of the kinetic energy that is converted into mechanical energy by the wind turbine [7].

Mechanical power, which is extracted, is given by:

$$P_m = \frac{1}{2} \rho A C_p(\lambda, \beta) v^3 \quad (5)$$

with

$$C_p(\lambda, \beta) = (0.5 - 0.0167 \cdot (\beta - 2)) \cdot \sin \left[\frac{\pi \cdot (\lambda + 0.1)}{18.5 - 0.3(\beta - 2)} \right] - 0.00184 \cdot (\lambda - 3) \cdot (\beta - 2) \quad (6)$$

where ρ is the air density ($\text{kg} \cdot \text{m}^{-3}$) and A is the rotor rotational area m^2 .

Figure 2 shows the $C_p = f(\lambda-\beta)$ curves for some β values. It can be seen that as β increases, C_p decreases, thus reducing the power produced by the WT.

Mechanical torque T_m is the ratio of mechanical power to turbine speed as given by:

$$T_m = \frac{P_m}{\omega} \quad (7)$$

The mechanical behaviour of the wind turbine follows:

$$J \frac{d\Omega_{mec}}{dt} + f\Omega_{mec} = T_{mec} \quad (8)$$

With: $T_{mec} = T_g - T_{em} \frac{1}{2}$

T_a is the torque applied to the DFIG rotor, T_{em} is the electromagnetic torque developed by the DFIG, J is the total inertia coefficient and f is the friction coefficient.

The gearbox is modelled by a simple gain G , therefore:

$$T_g = \frac{T_m}{G} \quad (9)$$

$$\Omega_{mec} = G\Omega_t \quad (10)$$




Figure 2. Power coefficient as a function of pitch angle β and tip-speed ratio λ

In the MPPT operation mode without speed controller, the rotor speed of the wind turbine can be adjusted to achieve an optimal tip-speed ratio λ_{opt} , which yields the maximum power coefficient C_{pmax} and, hence, the maximum power. The value of the λ_{opt} can be calculated from the maximum of the power coefficient curves versus the tip-speed ratio.

From Eq. (9), the mechanical reference speed is obtained by:

$$\Omega_{mec_ref} = G\lambda_{Cpmax} \frac{v}{R} \quad (11)$$

5. DFIG vector control

Wind turbine always operates with different dynamics, from minimum wind speed to maximum wind speed. Three wind speeds and two operation modes are possible. Their definitions are as given below [8, 9]:

The cut-in speed is the minimum wind speed at which the wind turbine will generate usable power. The rated speed is the minimum wind speed at which the wind turbine will generate its designated rated power. At very high wind speeds, most of the wind turbines are shut down for protection purposes. It is known as the cut-out speed.

6. Vector control strategy

In order to achieve a decoupled control of active and reactive power, stator-flux-oriented vector control scheme is used. In this case, the frequency and amplitude of the stator for grid voltage is assumed constant (stable grid). The strong coupling between the fluxes and currents makes controlling of the DFIG, particularly, difficult. Therefore, vector control, also known as oriented flux control, is used. The d - q reference frame is linked to the rotating field. The stator flux is oriented along the d -axis.

The above-mentioned assumptions lead to the following:

$$\begin{cases} u_{sd} = 0, & u_{sq} = V_s = \omega_s \varphi_s \\ \varphi_{sd} = \varphi_s, & \varphi_{sq} = 0 \end{cases} \quad (12)$$

Using the vector control, the active and reactive powers of the DFIG can be expressed as follows:

$$\begin{cases} P_s = -V_s \frac{L_m}{L_s} I_{rq} \\ Q_s = V_s \frac{\varphi_s}{L_s} - V_s \frac{L_m}{L_s} I_{rd} \\ P_s = S V_s \frac{L_m}{L_s} I_{rq} \\ P_s = S V_s \frac{L_m}{L_s} I_{rd} \end{cases} \quad (13)$$

7. Rotor-side converter control

The control principle of the RSC allows the control of active and reactive power and the extraction of maximum wind power. The power control loops generate the reference values of the d - and q -axes rotor currents for the current control loops (Figure 3).

Each control loop has a cascaded structure: a fast inner current control loop, controlling the rotor current, I_{dqr} , combined with an outer slower control loop for active and reactive power, respectively. An MPP-tracking provides the reference signal $P_{Grid,ref}$ for the active power, while the reactive power $Q_{Grid,ref}$ is generally set to zero. The slower power control loop has the reference rotor current signal, $I_{dq,Rotor,ref}$, as output, which is further used by the fast inner current control loop. Finally, the two control signals for the rotor voltage vector v_{dr} and v_{qr} are generated, which are sent to the PWM-controlled power converter [10].




Figure 3. Active and reactive power control of the DFIG

8. Simulation results

Simulation studies are carried out in Matlab Simulink. The simulation parameters of the DFIG wind turbine are given in Table 1 of Appendix A. Our aim is to make the stator active and reactive power control track its reference variations. The studied system has been tested for a step change of active reference power and reactive reference power as shown in Figure 4. The unity power factor is obtained by setting $Qf-ref = 0$. Figure 5 illustrates the stator and rotor voltages and currents of the DFIG wind turbine for the simulation test designed.

Figures 6 and 7 show the simulation results when controlling the DFIG with a PWM RSC.




Figure 4. Stator active and reactive powers of the DFIG




Figure 5. Three-phase stator and rotor voltages and currents




Figure 6. Stator active and reactive powers with PWM RSC control




Figure 7. Three-phase stator and rotor voltages and currents

9. Conclusion

This paper analysed the mathematical model of doubly fed induction generator and vector control strategy based on the stator flux orientation, established a dual-loop PI control that can realise the active and reactive powers decoupled control by adjusting the d and q components of the rotor current, respectively. The maximum power point tracking under the speed control mode and power control mode is discussed. The simulation results show that the dual-loop vector control strategy of doubly fed wind power generation system is valid and effective, and the power control mode is more suitable for practical application for its better stability than the speed control mode.

10. Nomenclature

DFIG wind turbine parameters and list of symbols are:

Rated power	1.5 MW
Rotor diameter	35.25 m
Gearbox ratio	90
Friction coefficient :	0.0024
Moment of inertia : J	1000
Stator voltage/Frequency	690 V/50 Hz
$R_s /R_r (\Omega)$	0.012/0.021
$L_m/L_s/L_r (H)$	0.0135/0.0137/0.013675
$R_f (H)/L_f (H)/C (F)$	0.000002/0.005/0.044
Number of pole pairs: p	2
V_{dc_ref}	2,000 V
P_s, Q_s	stator active and reactive power
P_r, Q_r	rotor active and reactive power
$P_{sd,q}$	stator $d-q$ frame voltage
$V_{sd,q}$	rotor $d-q$ frame voltage
$I_{sd,q}$	stator $d-q$ frame current
$I_{rd,q}$	rotor $d-q$ frame current

$\varphi_{sd,q}$	stator d - q frame flux
$\varphi_{rd,q}$	rotor d - q frame flux
R_s, L_s, R_r, L_r	stator and rotor resistances and inductances
L_m	mutual inductance
ω_s, ω_r	synchronous and rotor angular frequency

References

- [1] D. Fletcher and J. Yang, "Introduction to doubly-fed induction generator for wind power applications," Glasgow, United Kingdom: University of Strathclyde. www.intechopen.com, Paths to Sustainable Energy.
- [2] Barambones, *et al.* "Robust speed control for a variable speed wind turbine," *International Journal of Innovative Computing, Information and Control ICIC International*, Vol. 8, issue 11, November 2012.
- [3] K. Bedoud *et al.*, "Modélisation d'une chaîne de conversion d'énergie éolienne basée sur une machine asynchrone à double alimentation," in: *21ème Congrès Français de Mécanique Bordeaux*, 26 au 30 août 2013.
- [4] Mechter *et al.*, "Power control of the wind turbine for low wind speed," in: *Proceedings of the first international conference on nanoelectronics, communications and renewable energy*, 2013.
- [5] A. Acakpovi and E. B. Hagen, "A wind turbine system model using a doubly-fed induction generator (DFIG)," *International Journal of Computer Applications*, Vol. 90, issue 152014, pp.0975–8887, 2014.
- [6] D. Mary *et al.*, "Modelling and Simulation of Grid Connected Wind Energy System," *International Journal of Soft Computing and Engineering*, Vol. 2, issue 5, pp. 2231–2307, 2010.
- [7] A. W. Manyonge *et al.*, "Mathematical modelling of wind turbine in a wind energy conversion system: power coefficient analysis," *Applied Mathematical Sciences*, Vol. 6, issue 91, pp. 4527–4536, 2012.
- [8] W. Dingguo and W. Zhixin, "Modeling and design of control system for variable speed wind turbine in all operating region," *International journal of systems applications, engineering & development*, Vol. 1, issue 3, 2007.
- [9] F. Kendouli *et al.*, "Modélisation, simulation et contrôle d'une turbine éolienne à vitesse variable basée sur la génératrice asynchrone à double alimentation," *Revue des Energies Renouvelables*, Vol. 14, issue 1, pp. 109–120, 2011.
- [10] G. Gail *et al.*, "Controller design and analysis of a variable speed wind turbine with doubly-fed induction generator", University of Technology Darmstadt, Department of Renewable Energies, Institute for Electrical Power System